

Message Flow Details

MM00370 - Notification of Commissioning Information

Market Message Information

Market Message Reference	MM00370
MM Description	Half Hourly notification of Commissioning information which is transferred when there is a new connection, change in equipment, configuration or upon Change of Agent.
Local Catalogue Reference	D0383
Version	001
Notes	See Annex C for Flow Notes. - Where an AMVLP (Asset Metering Virtual Lead Party) is involved, the MPAN Core must contain an AMSID (Asset Metering System Identifier) and not an MPAN.

Scenario Variants

Scenario Variant	Name	Source	Target	Owner	Api Route	Api Method
SV00370	Notification of Commissioning Information	Distribution Network Operator	Electricity Meter Equipment Manager	Further Analysis Retail Energy Code Company		
SV00371	Notification of Commissioning Information	Electricity Meter Equipment Manager	Electricity Meter Equipment Manager	Retail Energy Code Company Further Analysis		
SV00446	Notification of Commissioning Information	Asset Metering Virtual Lead Party	Electricity Meter Equipment Manager	Retail Energy Code Company Further Analysis		
SVxxxxx	Notification of Commissioning Information	Distribution Network Operator	Electricity Meter Equipment Manager	Retail Energy Code Company		

SVxxxxx	Notification of Commissioning Information	Electricity Advanced Meter Equipment Manager	Electricity Advanced Meter Equipment Manager	Retail Energy Code Company		
SVxxxxx	Notification of Commissioning Information	Asset Metering Virtual Lead Party	Electricity Advanced Meter Equipment Manager	Retail Energy Code Company		

Flow Structure

MM00370 - Notification of Commissioning Information - Message Structure

Group ID	Group Description	Range	Condition	L1	L2	L3	L4	L5	L6	L7	L8	Data Item Name	Data Item Rule
95L	MPAN Cores	1-*		G									
					1							MPAN Core	
					1							Number of Feeders	
96L	Feeder Information	1-*		G									
						1						Feeder Id	
						1						Feeder Status	
						1						Measurement Transformers Located at Defined Metering Point	
						1						Number of Phases	
						1						CT Commissioning Information Available	
						1						VT Commissioning	

												Information Available	
						1						Meter Commissioning Information Available	
97L	CT Details	0-*	CT Details message collection is Mandatory if CT Commissioning Information Available data item value is equal to Y; or,CT Details message collection is Not Present if CT Commissioning Information Available data item value is equal to N.				G						
						1						Phase Id	
						1						Commissioning Date	
						1						Market Participant Role Code	
						1						Commissioning Agent MPID	
						1						CT Serial Number	
						1						CT Class	
						1						CT Rating	
						1						CT Ratio	

						1									Burden on CT	
						0									Overall Burden on CT (VA)	
98L	VT Details	0-*	VT Details message collection is Mandatory if VT Commissioning Information Available data item value is equal to Y; or, VT Details message collection is Not Present if VT Commissioning Information Available data item value is equal to N.				G									
						1									Phase Id	
						1									Commissioning Date	
						1									Market Participant Role Code	
						1									Commissioning Agent MPID	
						1									VT Serial Number	
						1									VT Class	
						1									VT Rating	
						1									VT Ratio	
						1									Burden on VT	

							0								Overall Burden on VT (VA)	
99L	Meter Details	0-0					G									
							1								Commissioning Date	
							1								Commissioning Agent MPID	
							1								Meter Id (Serial Number)	
							1								Meter Accuracy Class	
							1								CT Ratio	
							0								VT Ratio	
							1								Compensation Applied to Meter	